



# Florida Department of Environmental Protection

Northwest District  
160 Governmental Center  
Pensacola, Florida 32502-5794

Charlie Crist  
Governor

Jeff Kottkamp  
Lt. Governor

Michael W. Sole  
Secretary

April 2, 2009

## SENT VIA EMAIL

(bnboynton@aol.com)

(benpingree@mywakulla.com)

The Flowers Subdivision  
by: Ben C. Boynton, Owner  
2735 Millers Landing Road  
Tallahassee, Florida 32312

Wakulla County Board of County Commissioners  
by: Ben Pingree, County Administrator  
P.O. Box 1263  
Crawfordville, Florida 32327

Dear Mr. Boynton and Mr. Pingree:

We received a *Request For Approval To Place A Domestic Wastewater Collection/ Transmission System Into Operation*, DEP Form 62-604.300(8)(b), submitted by the Wakulla County Board of County Commissioners on March 19<sup>th</sup>, certifying the completion of construction of The Flowers Subdivision Pump Station No. 1. Construction of the pump station was authorized by the Crawfordville Roadway Sewer Extension project, permit number CS65-0134533-001-DWC/CG. As stated in our letter of June 6, 2008, completion of this pump station completes Phase I of The Flowers Subdivision, Phases I & II project, permit number CS65-0234608-003-DWC/CG, and removes the previously imposed 50-lot restriction on Phase I.

Our partial approval to utilize the Crawfordville Roadway Sewer Extension project, authorized by permit number CS65-0134533-001-DWC/CG, is granted. This partial approval includes utilization of The Flowers Pump Station No. 1 and the force main described by our clearance letter dated June 6, 2008. Final clearance for this project is pending resolution of force main separation deviations discovered after June 6, 2008.

Our partial approval to utilize Phase I of The Flowers Subdivision, Phases I & II project, authorized by permit number CS65-0234608-003-DWC/CG, is granted. This partial approval includes utilization of Pump Station No. 1 and 9,914 LF of gravity sewer main and 47 manholes described by our clearance letter dated June 6, 2006.

Our final approval to utilize the remaining portions of The Flowers Subdivision Phases I & II project is needed. Please note that permit number CS65-0234608-003-DWC/CG will expire on July 18, 2010; therefore, all remaining projects for this permit must be completed prior to this date or a new collection system permit will be required to complete the project.

Approval of individual connections to a completed collection/transmission system must be obtained from the authority responsible for operation and maintenance of the collection system and from the permittee of the treatment/disposal system.

Sincerely,



Allan E. Karrer  
Permitting Engineer  
Domestic Wastewater Section

Copy via email to:

Jeremy Reese, GPI Southeast, Inc. (jreese@gpinet.com)

Brent Pell, P.E., Project Engineer, ESG Operations Inc. (bpell@esginc.net)

David A. Freni, P.E., GPI Southeast, Inc. (dfreni@gpinet.com)

John D. Hewa, General Manager, Talquin Electric Cooperative, Inc.

(jhewa@talquinelectric.com)

Chair, Wakulla County Board of County Commissioners (hkessler@mywakulla.com)

Wakulla County Public Health Department (pardaic\_juarez@doh.state.fl.us)

FDEP Tallahassee Branch Office